

**System Losses
Maine Public Service Company**

<u>Voltage Category</u>	<u>Winter Energy Losses</u>	<u>non-Winter Energy Losses</u>	<u>Average Energy Losses</u>
Transmission	2.65%	1.61%	1.99%
Subtransmission	3.66%	2.81%	3.24%
Primary	5.12%	4.28%	4.68%
Secondary	8.09%	7.66%	7.86%
Average			6.17%

Maine Public Service Company's Line Loss Study may be obtained by contacting the Maine Public Utilities Commission at 207-287-3831 and referencing Docket No. 98-943.