

System Losses
Bangor Hydro-Electric Company

<u>Voltage Category</u>	<u>Energy Losses</u>
Transmission	1.59%
Subtransmission	2.98%
Primary	5.62%
Secondary	9.90%
Average	7.09%

System losses exclude losses over PTF facilities. Bangor Hydro-Electric Company's Line Loss Study may be obtained by contacting the Maine Public Utilities Commission at 207-287-3831 and referencing Docket No. 98-943.

